

DATA MONITORING - WATER FOR 2013-2014 REPORTING PERIOD

<b>Pollutant</b>	<b>Units</b>	<b>License Limits</b>	<b>EPA Monitoring Point 1 Results</b>
			<b>16/01/14</b>
<b>Amount discharged</b>	<b>KL</b>	<b>22000</b>	<b>5000</b>
<b>pH</b>	<b>pH</b>	<b>6.5-8.5</b>	<b>8.3</b>
<b>Conductivity</b>	<b>Microsiemens per centimetre</b>	<b>-</b>	<b>960</b>
<b>Oil and Grease</b>	<b>Milligrams per Litre</b>	<b>10</b>	<b>&lt;2</b>
<b>Total suspended Solids</b>	<b>Milligrams per Litre</b>	<b>50</b>	<b>7</b>
<b>Turbidity</b>	<b>Nephelometric turbidity units</b>	<b>150</b>	<b>20</b>

One lot of water has been discharged in this reporting period.